



## Declaration of Conformity

The manufacturer herewith declares that the Pressure Equipment in the supplied execution corresponds to the regulation as defined by Pressure Equipment Directive 2014/68/EU

**Manufacturer:**

Swissfluid AG  
Industriestrasse 40, CH-5600 Lenzburg



**Pressure Equipment:**

Butterfly Valves SBP Series, made of cast steel, with plastomeric linings

**Valve Rating:**

Size DN	Cat. PED	DIN Flange Standard	Size DN	ANSI Flange Standard	PS max. Op. Pressure DIN / ANSI
32 – 150	I, II	PN16	1 1/4" – 6"	150lbs	16 bar
200 – 600	II, III	PN10	8" – 24"	150lbs	10 bar
700 – 900	III	PN10	28" – 36"	150lbs	6 bar
1000	III	PN10	42"	150lbs	3 bar

**Applied Conformity Assessment Procedure:** Module H, Fluid Group 1

**Valve Testing:**

Size DN	Size DN	PT Testing Press. (Water) P12 Seat Tightness	PT Testing Press. (Water) P10/P11 Tightness and Mechanical Strength of Body
32 – 150	1 1/2" – 6"	17.6 bar	24.0 bar
200 – 600	8" – 24"	11.0 bar	15.0 bar
700 – 900	28" – 36"	6.6 bar	9.0 bar
1000	42"	3.3 bar	4.5 bar
P12: with air	40 – 600	6.0 bar	
	700 – 1000	3.0 bar	

The evidence of a quality assurance system according to the Pressure Equipment Directive PED 2014/68/EU, Annex III, Module H has been provided and was certified by the notified body 1253 (Swiss Safety Center) with Certificate **No. PED-Z-COS.EP.5500595 (valid until 16.12.2028).**

**Applied Standards:**

EN 19, EN 1983, EN 558-1, EN 1092-1/2, DIN EN 10213, EN 10204, EN 12266-1/2, EN 12516, ASME B16.10, ASME B16.5, ASME B16.34, API 598

**References for the operator acc. to the operating manual.**

Location: CH-5600 Lenzburg  
Date: 01.01.2026

**M. Meier** Managing Director:

**D. Krizanec** Q.A. Manager: